

Southmoor Elementary School (298)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/27/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
298-104-SK-01	Kitchen sanitation faucet, north wall, left faucet, only hot water plumbed	29.7	N/A	µg/L	No drinking notice
298-104-SK-02	Kitchen sink, north wall, middle faucet	4.0		µg/L	
298-104-SK-03	Kitchen sink, north wall, right faucet	2.9		µg/L	
298-104E-SK-04	Kitchen office sink, room 104F	10.1		µg/L	
298-101J-SK-05	Main office sink, room 101J	2.2		µg/L	
298-101A-SK-06	Main office sink, room 101A	1.1		µg/L	
298-106-DF-07	Drinking fountain, all purpose room, north wall next to kitchen	<1.0*1		µg/L	
298-106-DF-08	Drinking fountain, all purpose room, south wall next to stage	1.0		µg/L	
298-105-DF-09	Drinking fountain, hallway 105, across from room 107, left bubbler	<1.0		µg/L	
298-105-DF-10	Drinking fountain, hallway 105, across from room 107, right bubbler	<1.0		µg/L	
298-107-SK-11	Classroom sink, room 107	<1.0		µg/L	
298-108-DF-12	Drinking fountain, gymnasium, north corner	1.1		µg/L	
298-112-SK-13	Classroom sink, room 112	<1.0		µg/L	
298-113-SK-14	Classroom sink, room 113	<1.0		µg/L	
298-109-DF-15	Drinking fountain, hallway 109, next to room 113	<1.0		µg/L	
298-109-DF-16	Drinking fountain, hallway 109, next to room 115	<1.0		µg/L	
298-115-SK-17	Classroom sink, room 115	<1.0		µg/L	
298-116-SK-18	Classroom sink, room 116	<1.0		µg/L	
298-117-SK-19	Classroom sink, room 117	<1.0		µg/L	
298-117-DF-20	Drinking fountain, room 117	<1.0		µg/L	
298-118-SK-21	Classroom sink, room 118	1.6		µg/L	
298-118-DF-22	Drinking fountain, room 118	<1.0		µg/L	
298-122-SK-23	Classroom sink, room 122	4.0		µg/L	
298-123-SK-24	Classroom sink, room 123	1.6		µg/L	
298-123-DF-25	Drinking fountain, room 123	<1.0		µg/L	
298-124-SK-26	Classroom sink, room 124	1.3		µg/L	
298-125-SK-27	Classroom sink, room 125	<1.0		µg/L	
298-126-SK-28	Classroom sink, room 126	<1.0		µg/L	
298-128-SK-29	Classroom sink, room 128	1.4		µg/L	
298-100-DF-30	Drinking fountain, hallway 100, next to room 128	<1.0		µg/L	
298-100-DF-31	Drinking fountain, hallway 100, next to room 129	1.6		µg/L	

Phase II Sampled on 4/6/2017

298-103-SK-32	Classroom sink, room 103	<1.0	µg/L
298-130-SK-33	Classroom sink, room 130	3.0	µg/L
298-129-SK-34	Classroom sink, room 129	<1.0	µg/L
298-127-SK-35	Classroom sink, room 127	1.0	µg/L
298-121-SK-36	Classroom sink, room 121	2.0	µg/L
298-120-SK-37	Classroom sink, room 120	5.0	µg/L
298-111-SK-38	Classroom sink, room 111	1.0	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.