

Steck Elementary (276)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/30/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
276-107-DF-01	Drinking fountain, gym	<1.0* ¹		µg/L	
276-100-DF-02	Drinking fountain, hallway 100, next to gym	<1.0		µg/L	
276-102-DF-03	Drinking fountain, room 102	1.7		µg/L	
276-100-DF-04	Drinking fountain, hallway 100, next to room 109	<1.0		µg/L	
276-110-SK-05	Lounge sink, room 110	1.7		µg/L	
276-100-DF-06	Drinking fountain, hallway 100, next to auditorium	<1.0		µg/L	
276-200-DF-07	Drinking fountain, hallway 200, next to room 210	<1.0		µg/L	
276-200-DF-08	Drinking fountain, hallway 200, next to IMC LMC	<1.0		µg/L	
276-209A-SK-09	Sink, room 209A	3.8		µg/L	
276-200-DF-10	Drinking fountain, hallway 200, next to room 203	1.0		µg/L	
276-008A-SK-11	Kitchen sink, left	<1.0		µg/L	
276-008A-SK-12	Kitchen sink, right	3.6		µg/L	

Phase II Sampled on 2/7/2017

276-115-SK-13	Classroom sink, room 115	4.4		µg/L	
276-103-SK-14	Classroom sink, room 103	1.3		µg/L	
276-108-SK-15	Classroom sink, room 108	2.7		µg/L	
276-105-SK-16	Classroom sink, room 105	0.7		µg/L	
276-106-SK-17	Classroom sink, room 106	0.6		µg/L	
276-109-SK-18	Classroom sink, room 109	16.0	11.0	µg/L	Faucet replaced 9/2018
276-211-SK-19	Classroom sink, room 211	3.7		µg/L	
276-210-SK-20	Classroom sink, room 210	2.7		µg/L	
276-201-SK-21	Classroom sink, room 201	14.0		µg/L	
276-202-SK-22	Classroom sink, room 202	9.3		µg/L	
276-203-SK-23	Classroom sink, room 203	4.3		µg/L	
276-208-SK-24	Classroom sink, room 208	2.3		µg/L	
276-205-SK-25	Classroom sink, room 205	0.7		µg/L	
276-206-SK-26	Classroom sink, room 206	0.8		µg/L	

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.