

Steele Elementary (278)

All results below 15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/25/2016				
Sample ID	Sample Description	Lead Result	Units	Action
278-112B-DF-01	Drinking fountain, hallway 112B, between 112A and 112D	<1.0*	µg/L	
278-110-DF-02	Drinking fountain, hallway 110, next to room 111	<1.0	µg/L	
278-100-DF-03	Drinking fountain, hallway 100, next to room 101	<1.0	µg/L	
278-207-DF-04	Drinking fountain, hallway 207, across from room 210	<1.0	µg/L	
278-300-DF-05	Drinking fountain, hallway 300, outside of room 312	<1.0	µg/L	
278-303-DF-06	Drinking fountain, hallway 303, outside of room 308	<1.0	µg/L	
278-108-SK-07	Kitchen sink, left, east side	2.4	µg/L	
278-108-SK-08	Kitchen sink, right, east side	<1.0	µg/L	
278-108-SK-09	kitchen sink, far left	1.5	µg/L	
278-108-SK-10	Kitchen sink, west wall	5.7	µg/L	
278-108-SK-11	Kitchen sink, south wall	1.2	µg/L	
278-108-SK-12	Kitchen sink, north wall	3.8	µg/L	
278-107-DF-13	Drinking fountain, cafeteria, left bubbler	<1.0	µg/L	
278-107-DF-14	Drinking fountain, cafeteria, right bubbler	<1.0	µg/L	
278-107D-SK-15	PTA Sink, cafeteria room 107D	1.3	µg/L	
278-201E-SK-16	Nurse sink, room 201E	<1.0	µg/L	
278-200-DF-17	Drinking fountain, hallway 200, outside of room 200C	<1.0	µg/L	
278-209-SK-18	Sink, room 209	1.6	µg/L	
278-208AA-SK-19	Sink, room 208AA	10.5	µg/L	
Phase II Sampled on 1/20/2017				
278-112A-SK-20	ECE storage room sink, room 112A	2.0	µg/L	
278-113-SK-21	Classroom sink, room 113	1.0	µg/L	
278-114-SK-22	Classroom sink, room 114	3.0	µg/L	
278-115-SK-23	Classroom sink, room 115	1.0	µg/L	
278-101-SK-24	Classroom sink, room 101	<1.0	µg/L	
278-103-SK-25	Classroom sink, room 103	1.0	µg/L	
278-202-SK-26	Classroom sink, room 202	2.0	µg/L	
278-212-SK-27	Classroom sink, room 212	3.0	µg/L	
278-211-SK-28	Classroom sink, room 211	1.0	µg/L	
278-306-SK-29	Classroom sink, room 306	1.0	µg/L	
278-309-SK-30	Classroom sink, room 309	2.0	µg/L	
278-310-SK-31	Classroom sink, room 310	2.0	µg/L	
278-312-SK-32	Classroom sink, room 312	2.0	µg/L	
278-313-SK-33	Classroom sink, room 313	1.0	µg/L	
278-301-SK-34	Classroom sink, room 301	6.0	µg/L	

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.