

## Teller Elementary (281) – Sampled 08/24/2016 & 1/27/2017

All results below 15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF – drinking fountain, SK – sink) – consecutive sample number

Phase I Sampled on 8/24/2016				
Sample ID	Sample Description	Lead Result	Units	Action
281-110-SK-01	Kitchen sink, north wall by office	2.3	µg/L	
281-110-SK-02	Kitchen sink, east wall by storage	5.2	µg/L	
281-108-DF-03	Drinking fountain hallway 108, next to restrooms	<1.0* <sup>1</sup>	µg/L	
281-111-DF-04	Drinking fountain, gym	<1.0	µg/L	
281-105-DF-06	Drinking fountain hallway 105, right bubbler, by room 107	<1.0	µg/L	
281-140-DF-07	Drinking fountain hallway 140, by room 117	<1.0	µg/L	
281-200-DF-08	Drinking fountain hallway 200 by room 202	<1.0	µg/L	
281-200-DF-09	Drinking fountain hallway 200 by room 213, left bubbler	<1.0	µg/L	
281-200-DF-10	Drinking fountain hallway 200 by room 213, right bubbler	<1.0	µg/L	
281-204-SK-11	Faculty lounge sink	<1.0	µg/L	
281-200-DF-12	Drinking fountain hallway 200. next to 200E/200D	<1.0	µg/L	
281-300-DF-13	Drinking fountain hallway 300, across from elevator	<1.0	µg/L	
281-300-DF-15	Drinking fountain hallway 300, next to room 307, right bubbler	<1.0	µg/L	
Phase II Sampled on 1/27/2017				
281-104-SK-16	Classroom sink, room 104	0.4	µg/L	
281-112-SK-17	Classroom sink, room, 112	<0.1* <sup>2</sup>	µg/L	
281-103-SK-18	Classroom sink, room 103	0.4	µg/L	
281-116-SK-19	Classroom sink, room 116	<0.1	µg/L	
281-102-SK-20	Classroom sink, room 102	<0.1	µg/L	
281-117-SK-21	Classroom sink, room 117	0.2	µg/L	
281-101-SK-22	Classroom sink, room 101, sink on left	1.2	µg/L	
281-101-SK-23	Classroom sink, room 101, sink on right	0.3	µg/L	
281-118-SK-24	Classroom sink, room 118, sink on left	0.3	µg/L	
281-118-SK-25	Classroom sink, room 118, sink on right	6.4	µg/L	
281-215-SK-26	Classroom sink, room 215	0.4	µg/L	
281-214-SK-27	Classroom sink, room 214	<0.1	µg/L	
281-201-SK-28	Classroom sink, room 201	0.7	µg/L	
281-202-SK-29	Classroom sink, room 202	0.3	µg/L	
281-213-SK-30	Classroom sink, room 213	1.6	µg/L	
281-203A-SK-31	Nurse sink, room 203A	0.4	µg/L	

<b>281-211-SK-32</b>	Classroom sink, room 211	0.2	µg/L
<b>281-205-SK-33</b>	Conference room sink, room 205	0.7	µg/L
<b>281-304-SK-34</b>	Classroom sink, room 304	0.3	µg/L
<b>281-305-SK-35</b>	Classroom sink, room 305	0.2	µg/L
<b>281-306-SK-36</b>	Classroom sink, room 306	0.5	µg/L
<b>281-303-SK-37</b>	Classroom sink, room 303	0.2	µg/L
<b>281-302-SK-38</b>	Classroom sink, room 302	0.3	µg/L
<b>281-307-SK-39</b>	Classroom sink, room 307	0.3	µg/L
<b>281-308-SK-40</b>	Classroom sink, room 308	0.2	µg/L
<b>281-301-SK-41</b>	Classroom sink, room 301	0.3	µg/L
<b>281-212A-SK-42</b>	LMC/IMC office sink, room 212A	0.3	µg/L
<b>281-107-SK-43</b>	Classroom sink, room 107	0.2	µg/L

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

\*2. Result less than 0.1 ppb which is the lowest level that can be reported by the external lab.