

Thomas Jefferson High School (457)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled 11/19/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
457-01-DF-01	Drinking fountain, hallway 01, across from stair A, left bubbler	1.8		µg/L	
457-01-DF-02	Drinking fountain, hallway 01, across from stair A, right bubbler	1.2		µg/L	
457-01-DF-03	Drinking fountain, hallway 01, next to room 02, left bubbler	0.8		µg/L	
457-01-DF-04	Drinking fountain, hallway 01, next to room 02, right bubbler	0.6		µg/L	
457-20-DF-05	Drinking fountain, hallway 20, next to room 23E, left bubbler	9.2		µg/L	
457-20-DF-06	Drinking fountain, hallway 20, next to room 23E, right bubbler	4.9		µg/L	
457-04-SK-07	Classroom sink, room 04	1.7		µg/L	
457-08-DF-08	Drinking fountain, hallway 08, across from room 16, left bubbler	0.9		µg/L	
457-08-DF-09	Drinking fountain, hallway 08, across from room 16, right bubbler	1.0		µg/L	
457-116-DF-10	Drinking fountain, hallway 116, next to room 116B, left bubbler	1.0		µg/L	
457-116-DF-11	Drinking fountain, hallway 116, next to room 116B, right bubbler	0.9		µg/L	
457-116-DF-12	Drinking fountain, hallway 116, next to room 116D, left bubbler	2.0		µg/L	
457-116-DF-13	Drinking fountain, hallway 116, next to room 116D, right bubbler	1.4		µg/L	
457-124-SK-14	Faculty lounge sink, room 124	5.3		µg/L	
457-100-DF-15	Drinking fountain, hallway 100, next to room 112A, left bubbler	2.3		µg/L	
457-100-DF-16	Drinking fountain, hallway 100, next to room 112A, right bubbler	0.7		µg/L	
457-102-DF-17	Drinking fountain, hallway 102, next to room 102B, left bubbler	0.9		µg/L	
457-102-DF-18	Drinking fountain, hallway 102, next to room 102B, right bubbler	0.7		µg/L	
457-112B-SK-19	Workroom sink, room 112B	4.5		µg/L	
457-114B-SK-20	Nurse sink, room 114B	1.6		µg/L	
457-101-DF-21	Drinking fountain, cafeteria 101, south wall, east side, left bubbler	3.3		µg/L	
457-101-DF-22	Drinking fountain, cafeteria 101, south wall, east side, right bubbler	2.4		µg/L	

457-101-DF-23	Drinking fountain, cafeteria 101, south wall, west side, left bubbler	7.4		µg/L	
457-101-DF-24	Drinking fountain, cafeteria 101, south wall, west side, right bubbler	3.1		µg/L	
457-101A-DF-25	Drinking fountain, room 101A, next to kitchen 101B	25.0	20.0	µg/L	Bubbler replaced 5/2018; Fountain removed 4/2019
457-101B-SK-26	Food prep sink, kitchen 101B, west wall	1.9		µg/L	
457-101B-SK-27	kettle fill, kitchen 101B, center of room	1.9		µg/L	
457-101B-SK-28	Food prep sink, kitchen 101B, center of room	1.1		µg/L	
457-101B-SK-29	Food prep sink, kitchen 101B, east wall	1.3		µg/L	
457-146-DF-30	Drinking fountain, hallway 146, next to room 146F, left bubbler	2.4		µg/L	
457-146-DF-31	Drinking fountain, hallway 146, next to room 146F, right bubbler	1.1		µg/L	
457-146-DF-32	Drinking fountain, hallway 146, next to 146B	9.3		µg/L	
457-147-DF-33	Drinking fountain, hallway 147, across from room 149	2.4		µg/L	
457-142-DF-34	Drinking fountain, gymnasium 142, southeast corner	1.3		µg/L	
457-142-DF-35	Drinking fountain, gymnasium 142, southwest corner	1.2		µg/L	
457-142-DF-36	Drinking fountain, gymnasium 142, northeast corner	1.9		µg/L	
457-142-DF-37	Drinking fountain, gymnasium 142, northwest corner	2.9		µg/L	
457-145-DF-38	Drinking fountain, swim pool 145, northwest corner	1.0		µg/L	
457-145-DF-39	Drinking fountain, swim pool 145, northeast corner	1.9		µg/L	
457-143-DF-40	Drinking fountain, auxiliary gymnasium 143, southeast corner	3.6		µg/L	
457-141-DF-41	Drinking fountain, weight room 141, north wall, left bubbler	0.4		µg/L	
457-141-DF-42	Drinking fountain, weight room 141, north wall, right bubbler	0.4		µg/L	
457-205-DF-43	Drinking fountain, hallway 205, across from room 223, left bubbler	0.9		µg/L	
457-205-DF-44	Drinking fountain, hallway 205, across from room 223, right bubbler	0.8		µg/L	
457-200-DF-45	Drinking fountain, hallway 200, next to room 205A, left bubbler	0.8		µg/L	
457-200-DF-46	Drinking fountain, hallway 200, next to room 205A, right bubbler	0.9		µg/L	
457-204A-SK-47	LMC/IMC sink, room 204A	3.3		µg/L	
457-200-DF-48	Drinking fountain, hallway 200, next to room 200C, left bubbler	2.1		µg/L	
457-200-DF-49	Drinking fountain, hallway 200, next to room 200C, right bubbler	2.4		µg/L	
457-230-DF-50	Drinking fountain, hallway 230, next to room 230, left bubbler	4.6		µg/L	
457-230-DF-51	Drinking fountain, hallway 230, next to room 230, right bubbler	5.3		µg/L	
Phase II Sampled 10/27/2018					
457-05-SK-52	Classroom sink, room 05	3.0		µg/L	
457-06-SK-53	Classroom sink, room 06	<1.0		µg/L	

457-07-SK-54	Classroom sink, room 07	6.0		µg/L	
457-38-SK-55	Staff office sink, room 38	4.0		µg/L	
457-35-SK-56	Art room sink, room 35	<1.0		µg/L	
457-35A-SK-57	Art room sink, room 35A	<1.0		µg/L	
457-33-SK-58	Classroom sink, room 33	1.0		µg/L	
457-32A-SK-59	Office sink, room 32A	<1.0		µg/L	
457-31-SK-60	Art room sink, room 31, right faucet	4.0		µg/L	
457-31-SK-61	Art room sink, room 31, left faucet	2.0		µg/L	
457-111A-SK-62	Community room sink, room 111A	4.0		µg/L	
457-110-SK-63	Classroom sink, room 110, left faucet	6.0		µg/L	
457-110-SK-64	Classroom sink, room 110, right faucet	3.0		µg/L	
457-109-SK-65	Classroom sink, room 109, left faucet	34.0	20.0	µg/L	Failed – no drinking notice; Faucet replaced 5/2018
457-109-SK-66	Classroom sink, room 109, right faucet	30.0	12.0	µg/L	Faucet replaced 5/2018
457-108-SK-67	Classroom sink, room 108	3.0		µg/L	
457-148-SK-68	Music room sink, room 148	8.0		µg/L	
457-149-SK-69	Music room sink, room 149	4.0		µg/L	
457-134-SK-70	Science lab sink, room 134, north wall, left faucet	4.0		µg/L	
457-134-SK-71	Science lab sink, room 134, north wall, right faucet	4.0		µg/L	
457-134-SK-72	Science lab sink, room 134, south wall, left faucet	5.0		µg/L	
457-134-SK-73	Science lab sink, room 134, south wall, center faucet	2.0		µg/L	
457-134-SK-74	Science lab sink, room 134, south wall, right faucet	3.0		µg/L	
457-134-SK-75	Science lab sink, room 134, demonstration sink	4.0		µg/L	
457-132A-SK-76	Science prep room sink, room 132A	18.0		µg/L	Science Lab Notice
457-132-SK-77	Science lab sink, room 132, south wall, left faucet	2.0		µg/L	
457-132-SK-78	Science lab sink, room 132, south wall, center faucet	3.0		µg/L	
457-132-SK-79	Science lab sink, room 132, north wall, right faucet	3.0		µg/L	
457-132-SK-80	Science lab sink, room 132, north wall, left faucet	5.0		µg/L	
457-132-SK-81	Science lab sink, room 132, south wall, right faucet	2.0		µg/L	
457-132-SK-82	Science lab sink, room 132, demonstration sink	1.0		µg/L	
457-120-SK-83	Science lab sink, room 120, demonstration sink	20.0		µg/L	Science Lab Notice
457-120-SK-84	Science lab sink, room 120, east wall, left faucet	26.0		µg/L	Science Lab Notice
457-120-SK-85	Science lab sink, room 120, east wall, center faucet	19.0		µg/L	Science Lab Notice
457-120-SK-86	Science lab sink, room 120, east wall, right faucet	23.0		µg/L	Science Lab Notice
457-120-SK-87	Science lab sink, room 120, west wall, left faucet	17.0		µg/L	Science Lab Notice

457-120-SK-88	Science lab sink, room 120, west wall, center faucet	13.0	µg/L	
457-120-SK-89	Science lab sink, room 120, west wall, right faucet	13.0	µg/L	
457-119-SK-90	Science lab sink, room 119, west wall	15.0	µg/L	Science Lab Notice
457-119-SK-91	Science lab sink, room 119, south end	4.0	µg/L	
457-119-SK-92	Science lab sink, room 119, east wall	7.0	µg/L	
457-118-SK-93	Science lab sink, room 118, south end	22.0	µg/L	Science Lab Notice
457-118-SK-94	Science lab sink, room 118, west wall, 1st from south wall	10.0	µg/L	
457-118-SK-95	Science lab sink, room 118, west wall, 2nd from south wall	13.0	µg/L	
457-118-SK-96	Science lab sink, room 118, west wall, 3rd from south wall	9.0	µg/L	
457-118-SK-97	Science lab sink, room 118, west wall, 4th from south wall	6.0	µg/L	
457-118-SK-98	Science lab sink, room 118, west wall, 5th from south wall	5.0	µg/L	
457-118-SK-99	Science lab sink, room 118, demonstration sink	>50.0	µg/L	Science Lab Notice
457-118A-SK-100	Science prep room sink, room 118A	12.0	µg/L	
457-118B-SK-101	Science prep room sink, room 118B	>50.0	µg/L	Science Lab Notice
457-211-SK-102	Science lab sink, room 211, west wall, left faucet	16.0	µg/L	Science Lab Notice
457-211-SK-103	Science lab sink, room 211, west wall, center faucet	12.0	µg/L	
457-211-SK-104	Science lab sink, room 211, west wall, right faucet	8.0	µg/L	
457-211-SK-105	Science lab sink, room 211, east wall, far left faucet	9.0	µg/L	
457-211-SK-106	Science lab sink, room 211, east wall, center left faucet	13.0	µg/L	
457-211-SK-107	Science lab sink, room 211, east wall, center faucet	12.0	µg/L	
457-211-SK-108	Science lab sink, room 211, east wall, center right faucet	14.0	µg/L	
457-211-SK-109	Science lab sink, room 211, east wall, far right faucet	23.0	µg/L	Science Lab Notice
457-211-SK-110	Science lab sink, room 211, demonstration faucet	29.0	µg/L	Science Lab Notice
457-212A-SK-111	Science prep room sink, room 212A	15.0	µg/L	Science Lab Notice
457-212-SK-112	Science lab sink, room 212, demonstration faucet	13.0	µg/L	
457-212-SK-113	Science lab sink, room 212, east wall, far left faucet	10.0	µg/L	
457-212-SK-114	Science lab sink, room 212, east wall, center left faucet	17.0	µg/L	Science Lab Notice
457-212-SK-115	Science lab sink, room 212, east wall, center right faucet	11.0	µg/L	
457-212-SK-116	Science lab sink, room 212, east wall, far right faucet	9.0	µg/L	
457-212-SK-117	Science lab sink, room 212, west wall, left faucet	21.0	µg/L	Science Lab Notice
457-212-SK-118	Science lab sink, room 212, west wall, center faucet	20.0	µg/L	Science Lab Notice
457-212-SK-119	Science lab sink, room 212, west wall, right faucet	16.0	µg/L	Science Lab Notice