

University Park Elementary (284) – Sampled 08/26/2016

All results at 15 ppb or below – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF – drinking fountain, SK – sink) – consecutive sample number

Phase I Sampled on 8/26/2016				
Sample ID	Sample Description	Lead Result	Units	Action
284-005-DF-01	Drinking fountain, cafeteria	5.3	µg/L	
284-115A-DF-02	Drinking fountain, between rooms 115 and 116	1.7	µg/L	
284-117-DF-03	Drinking fountain, outside of room 117, in hallway 111	1.9	µg/L	
284-104-SK-04	Lounge sink, room 104	<1.0* ¹	µg/L	
284-105-DF-05	Drinking fountain, outside of room 105, in hallway 100	2.5	µg/L	
284-100C-DF-06	Drinking fountain, outside of room 100C, in hallway 100	2.0	µg/L	
284-110-DF-07	Drinking fountain, outside of 110, in hallway 100, across from room 102	<1.0	µg/L	
284-216-DF-08	Drinking fountain, outside of room 216, in hallway 211	1.3	µg/L	
284-210-DF-09	Drinking fountain outside of room 210, in hallway 200	<1.0	µg/L	
284-200B-DF1-10	Drinking fountain outside of room 207, in hallway 200	14.6	µg/L	
284-006-SK-11	Kitchen sink, left	<1.0	µg/L	
284-006-SK-12	Kitchen sink, middle	<1.0	µg/L	
284-006-SK-13	Kitchen sink, right	<1.0	µg/L	
Phase II Sampled on 2/7/2017				
284-106-SK-14	Classroom sink, room 106	0.6	µg/L	
284-105-SK-15	Classroom sink, room 105	0.5	µg/L	
284-103-SK-16	Classroom sink, room 103	0.7	µg/L	
284-102-SK-17	Classroom sink, room 102	1.1	µg/L	
284-101B-SK-18	Nurse sink, room 101B	0.8	µg/L	
284-119-SK-19	Classroom sink, room 119	1.3	µg/L	
284-113-SK-20	Classroom sink, room 113	0.5	µg/L	
284-117-SK-21	Classroom sink, room 117	0.5	µg/L	
284-118-SK-22	Classroom sink, room 118	<0.5* ²	µg/L	
284-114-SK-23	Classroom sink, room 114	0.5	µg/L	
284-116-SK-24	Classroom sink, room 116	<0.5	µg/L	
284-115-SK-25	Classroom sink, room 115	0.6	µg/L	
284-214-SK-26	Classroom sink, room 214	0.6	µg/L	
284-215-SK-27	Classroom sink, room 215	0.6	µg/L	
284-213-SK-28	Classroom sink, room 213	1.6	µg/L	
284-216-SK-29	Classroom sink, room 216	0.5	µg/L	
284-217-SK-30	Classroom sink, room 217	0.9	µg/L	
284-218-SK-31	Classroom sink, room 218	0.5	µg/L	
284-212-SK-32	Classroom sink, room 212	0.6	µg/L	
284-219-SK-33	Classroom sink, room 219	1.0	µg/L	

284-201-SK-34	Classroom sink, room 201	5.4	µg/L
284-202-SK-35	Classroom sink, room 202	1.6	µg/L
284-203-SK-36	Classroom sink, room 203	1.1	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

*2. Result less than 0.5 ppb which is the lowest level that can be reported by the external lab