

Valverde Elementary (285)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/24/2016					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
285-020-DF-01	Drinking fountain hallway 020	<1.0* ¹		µg/L	
285-120-DF-02	Drinking fountain hallway 120, left	1.5		µg/L	
285-112-DF-03	Drinking fountain room 112, right	2.1		µg/L	
285-113-DF-04	Drinking fountain room 113, right	<1.0		µg/L	
285-100-DF-05	Drinking fountain hallway 100, left, next to 100B	<1.0		µg/L	
285-102D-SK-06	Room 102D sink, nurse's room	27.5	3.0	µg/L	Faucet replaced 9/2018
285-102E-SK-07	Room 102E sink	<1.0		µg/L	
285-100-DF-08	Drinking fountain hallway 100, left, next to 100A	<1.0		µg/L	
285-108-DF-09	Drinking fountain in room 108, left	1		µg/L	
285-109-SK-10	Kitchen sink, left	<1.0		µg/L	
285-109-SK-11	Kitchen sink, right	2.5		µg/L	
285-110-DF-12	Drinking fountain room 110, north end	<1.0		µg/L	
285-110-DF-13	Drinking fountain room 110, south end	1.2		µg/L	
285-111-DF-14	Drinking fountain room 111, north end	<1.0		µg/L	
285-111-DF-15	Drinking fountain room 111, south end	<1.0		µg/L	
285-215-DF-16	Drinking fountain hallway 215, right	1.6		µg/L	
285-200-DF-17	Drinking fountain hallway 200, right, next to 200B	1.9		µg/L	
285-200-DF-18	Drinking fountain hallway 200, right, next to 200A	1.1		µg/L	
285-213-SK-19	Room 213 sink	1.2		µg/L	
285-212-SK-20	Room 212 sink	<1.0		µg/L	
Phase II Sampled on 1/26/2017					
285-116-SK-21	Classroom sink, room 116	1.1		µg/L	
285-101-SK-22	Classroom sink, room 101	>50.0	3.0	µg/L	Faucet replaced 9/2018
285-115-SK-23	Classroom sink, room 115	0.7		µg/L	
285-114-SK-24	Classroom sink, room 114	0.9		µg/L	
285-103-SK-25	Classroom sink, room 103	0.6		µg/L	
285-104-SK-26	Classroom sink, room 104	0.4		µg/L	
285-105-SK-27	Classroom sink, room 105	10.2		µg/L	
285-112-SK-28	Classroom sink, room 112	1.7		µg/L	
285-111-SK-29	Classroom sink, room 111, sink on left	1.1		µg/L	
285-111-SK-30	Classroom sink, room 111, sink on right	0.4		µg/L	

285-110-SK-31	Classroom sink, room 110, sink on left	0.7	µg/L
285-110-SK-32	Classroom sink, room 110, sink on right	1.5	µg/L
285-002-SK-33	Classroom sink, room 002	3.5	µg/L
285-003-SK-34	Classroom sink, room 003	0.7	µg/L
285-206-SK-35	Classroom sink, room 206	3.7	µg/L
285-205-SK-36	Classroom sink, room 205	0.2	µg/L
285-210-SK-37	Classroom sink, room 210	0.9	µg/L
285-211-SK-38	Classroom sink, room 211	1.4	µg/L
285-202-SK-39	Classroom sink, room 202	1.1	µg/L
285-212-SK-40	Classroom sink, room 212	0.3	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.