

## Whittier Elementary (289)

All results at 15 ppb or below – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/26/2016			
Sample ID	Sample Description	Lead Result	Units
289-02-SK-01	Kitchen sink, left	1.1	µg/L
289-02-SK-02	Kitchen sink, right	1.8	µg/L
289-01-DF-03	Drinking fountain, cafeteria	8.7	µg/L
289-212-SK-04	Sink, room 212	5.6	µg/L
289-110-DF-05	Drinking fountain, hallway 110, left bubbler	<1.0* <sup>1</sup>	µg/L
289-110-DF-06	Drinking fountain, hallway 110, right bubbler	<1.0	µg/L
289-114-SK-07	Sink, room 114	10.1	µg/L
289-100-DF-08	Drinking fountain, hallway 100, next to 100B	4.3	µg/L
289-116-SK-09	Lounge sink, room 116	5.9	µg/L
289-117-DF-10	Drinking fountain, hallway 117, left bubbler	<1.0	µg/L
289-117-DF-11	Drinking fountain, hallway 117, right bubbler	1.2	µg/L
289-118-DF-12	Drinking fountain, room 118	6.1	µg/L
289-118-DF-13	Drinking fountain, room 119	8.5	µg/L
289-200-DF-14	Drinking fountain, hallway 200, left bubbler	<1.0	µg/L
289-200-DF-15	Drinking fountain, hallway 200, right bubbler	<1.0	µg/L
289-101-DF-16	Drinking fountain, lobby 101, left bubbler	<1.0	µg/L
289-101-DF-17	Drinking fountain, lobby 101, right bubbler	<1.0	µg/L
Phase II Sampled on 2/9/2017			
289-114-SK-18	Classroom sink, room 114	4.7	µg/L
289-115-SK-19	Classroom sink, 115	6.5	µg/L
289-125-SK-20	Classroom sink, room 125	14	µg/L
289-124-SK-21	Classroom sink, room 124	13	µg/L
289-123-SK-22	Classroom sink, room 123	12	µg/L
289-118-SK-23	Classroom sink, room 118	2.3	µg/L
289-119-SK-24	Classroom sink, room 119	9.6	µg/L
289-120-SK-25	Classroom sink, room 120, left sink	1.3	µg/L
289-120-SK-26	Classroom sink, room 120, right sink	0.8	µg/L
289-121-SK-27	Classroom sink, room 121, left sink	0.8	µg/L
289-121-SK-28	Classroom sink, room 121, right sink	0.9	µg/L
289-122-SK-29	Classroom sink, room 122	10.0	µg/L
289-103-SK-30	Nurse sink, room 103	0.9	µg/L
289-102-SK-31	Admin office sink, room 102	1.2	µg/L
289-104-SK-32	Community room sink, room 104	2.8	µg/L

<b>289-209-SK-33</b>	Classroom sink, room 209	1.0	µg/L
<b>289-208-SK-34</b>	Classroom sink, room 208	8.5	µg/L
<b>289-207-SK-35</b>	Classroom sink, room 207	4.1	µg/L
<b>289-206-SK-36</b>	Classroom sink, room 206	10.0	µg/L
<b>289-205-SK-37</b>	Classroom sink, room 205	9.5	µg/L
<b>289-203-SK-38</b>	LMC/IMC office sink, room 203	8.6	µg/L
<b>289-112D-SK-39</b>	Gymnasium office sink, room 112D	5.3	µg/L

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.